

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-0028:141

Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Lawrence Flood (203) 484-1200 *FAX (203) 484-7309

DESIGN: Models AFP-1010 and AM-2020 fire alarm control units. Inherently power-limited; coded, non-coded and march time; local, proprietary and central station service; manual, automatic, waterflow and sprinkler supervisory service. Also suitable for releasing service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

DIA-1/-2/-1010/-2020	Display Interface Assembly
LIB-200/-200A/-400	Loop Interface Board
SIB-232/-2048/-2048A	Serial Interface Board
CPU-1010/-2020	Central Processor Board
ICA-4/-4L	Interconnect Assembly
MPS-24/-24A/-24B	Main Power Supply
CAB series	Enclosure
BP-1/-3, DP-1, DPDW-1	Dress Panel
STS-1	Tamper Switch
CRT-1/CRT-2	Terminal With Keyboard
MON-1	Monitor
P-80/PRN-2/PRN-3	Printer
SIB-64	Serial Interface Board
UZC-256	Universal Zone Coder
MPS-TR	Trouble Relay
NRT-M13W/-M13F	Network Reporting Terminals
NRT-M19W/-M19F	Network Reporting Terminals
NRT-NET	Network Module
MIB-F/-W/-WF	Media Interface Board
RPT-F/-W/-WF	Repeater Module
INA	Intelligent Network Annunciator
SIB-NET	Serial Interface Board
ABS-4D/ABF-4	INA Cabinet
ICA-4L	Interconnect Chassis Assembly
XPP-1/XPM-8/XPM-8L/XPR-8/XPC-8	XP Transponder
RACK-51/-67	19" Rack
ISO-X	Isolator Module
NR45-24	Battery Charger
AVPS-24	Audio/Visual Power Supply
MPM-2	Power Supply Meter

MOD-1/-6	Mounting Plate
CCM-1	Communications Converter Module
ADP/DIA/DPDW/DP/CHS/CRT/KB-xxx	Dress Panels
CAP-1	Capacitor
MBT-1	Municipal Box Trip
RPT-680	Remote Polarity Trip
NIB-96	Network Interface Board
NCM-1	Noise Control Module
N-ELR	EOL Resistor
RPJ-1	Remote Page Jack
MMX-1/-101	Monitor Module
NRT-586P, NRT-586T	Computer
NRT-LP	Light Pen and Controller Card
MON-17B, MON-21, MON-19	Monitor
NCS-M17W, -M17F, -M17WF	Network Control Station
NCS-L17W, -L17F, -L17WF	
NCS-M21W, -M21F, -M21WF	
NCS-L21W, -L21F, -L21WF	
NCS-L19W, -L19F, -L19WF	
NCS-M19W, -M19F, -M19WF	

Refer to CSFM Listing No. 7170-0028:153 for additional optional accessories.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

Central Station: Suitable for central station (PPU) service when used with separately listed electrically compatible DACT.

NOTE: Combined with 7165-0028:159

*Rev. 05-01-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division